WATER SAMPLE REPORT (Chemical test) 889

Sl. No.	Name of the Grampanchayat	Name of the Village	Name of Habitation	Source	PH Value	Chloride mg/I	Total Iron mg/I	Dissolved Iron mg/I	Fluoride mg/I	Hardness mg/I CaCO3	Alkinity mg/l	Remarks
1)	Bhawanipatna		Kendriya-vidyalaya. Bhawanipatna.	T/W	–	60	0.07	–	0.67	128	240	
			Permissible limits		–	Upto 1000 mg/L	Upto 1.00 mg/L	–	Upto 1.50 mg/L	Upto 600 mg/L as CaCO3	Upto 600 mg/L	

Sthed
25-02-2021
Junior Laboratory Assistant
Dist. Rural Water Testing Laboratory
Kalahandi, Bhawanipatna

Executive Engineer
Kalahandi RWS&S Division
Bhawanipatna

24.05.2021
PRINCIPAL
K.V. BHAWANIPATNA